

NOTICE INVITING QUOTATIONS FROM ALL THE INTERESTED PARTIES THROUGH THIS OPEN INVITATION.

Date: 05-11-2020

Dear Sir/Madam,

Presently we have Ceasefire Products as per the description given below installed in the extended Server Room of the University Computer Centre located at the ground floor of the Academic Block of the Engineering Departments.

The University intends to make purchase of the new (same or equivalent to the product)/ refill the existing products of the following fire extinguishers as per the specifications given below: Technical Specifications				
Products	Capacity	Quantity	Installation Place	Remarks
Ceiling Mounted Clean Agent HCFC 123 CM Discharge time min. 10 seconds Auto discharge mechanism on temperature rise applicable class A, B, C, & electrically started fire	5 Kg	01	To be installed in the Extended Server of the University Computer Centre located at the ground floor of Academic Block of the Engineering Departments	Should be safe and should not damage switches, server, UPS and other electronics equipment/ electrical equipment when used
MAP 90 applicable class A, B, C, & electrically started fire ISI & CE approved	2 Kg	01		
Ceiling Mounted SP MAP 90 CM Discharge time min. 8 seconds Auto discharge mechanism on temperature rise applicable to electrically started fire	5 Kg	01		

11/5/20
S. S. - Sharma

Please give your offer for the three options as per the details tabulated below. Make sure that rates quoted are inclusive of all taxes, levies, installation and FOR Punjabi University Patiala.


Product	Capacity	Quantity	Option-I	Option-II	Option-III
			Refill of existing ceasefire products	Buy back of existing ceasefire products	New Products rates
Ceiling Mounted Clean Agent HCFC 123 CM Discharge time min. 10 seconds Auto discharge mechanism on temperature rise applicable class A, B, C, & electrically started fire	5 Kg	01			

MAP 90 applicable class A, B, C, & electrically started fire ISI & CE approved	2 Kg	01			
Ceiling Mounted SP MAP 90 CM Discharge time min. 8 seconds Auto discharge mechanism on temperature rise applicable to electrically started fire	5 Kg	01			

Terms and Conditions:

1. Rates must be all inclusive along with installation in INR FOR Punjabi University, Patiala
2. Payment will be made on successful installation on bill payment basis.
3. Product shall have shell life of at least five years or more.

Please send your quotations on or before 26.11.2020 by 4:00 pm, preferably in the sealed envelope mentioning "Quotation for Fire Extinguishers" on the top of it. You are welcome to visit the extended Server room of the University Computer Centre in the Academic Block of Engineering Departments to make assessment of the installed equipment in case of any clarification please contact Sh. Santbir Singh (M-9914599399) or Smt. Vibhu Sharma (M- 9855870530). Please note that the collective order of all the equipment will be ordered to the one vendor only.

 5/11/2020

Dr. Kawaljeet Singh

Director, University Computer Centre,
2nd Floor, UGC Human Resource Development Centre Building, Science Department Blocks
PUNJABI UNIVERSITY, PATIALA 147002
NH 64, Next to Urban Estate Phase-II (From Patiala Side)
Punjab (India)
91(175)5136314/ 15; director@pbi.ac.in, singhkawaljeet@pbi.ac.in
=====